

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF FLEMING COUNTY WATER)	
ASSOCIATION, INC. FOR A DEVIATION FROM)	
807 KAR 5:066, SECTION 4(4), REGARDING)	CASE NO. 92-283
WATER STORAGE)	

O R D E R

By letter filed on July 6, 1992, the Fleming County Water Association, Inc. ("Fleming Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. On February 29, 1988, the Commission ordered Fleming Water to bring its water storage facilities into compliance with Commission regulations by February 28, 1991.

On July 6, 1992, Fleming Water informed the Commission that it has a contract with Kentucky Glass Lined Tank Company to erect a 200,000-gallon water storage tank. This tank construction, which was approved by the Commission on June 15, 1992, was tentatively scheduled to start July 6, 1992.

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that Fleming Water is making a good faith effort toward bringing its facilities into compliance with Commission regulations and that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:

1. Fleming Water be and it hereby is granted a deviation until July 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Fleming Water shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1993.

Done at Frankfort, Kentucky, this 4th day of August, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director, Acting